

STANDARD ABBREVIATIONS

The list of abbreviations given below is not comprehensive; these abbreviations may or may not be incorporated into the Contract Documents and abbreviations not listed may be used. Periods may or may not be shown after the abbreviation.

Abbreviations are given usually for the singular case - for the plural case, the same abbreviation without adding the 's' may be used.

While upper case letters are shown, either upper case or lower case letters may be used in Specifications.

The following is listed alphabetically by the complete word, not by the abbreviation.

ABBREVIATION	COMPLETE WORD
ASD	Allowable Stress Design
ALT	Alternate
ACI	American Concrete Institute
AI	American Institute of Steel Construction
ASTM	American Society of Mechanical Engineers
ASCE	American Society of Civil Engineers
ANS	American Nuclear Society
APPROX	Approximate
ARCH	Architectural
6x	6 x (length unit) on Center
B to B	Back to Back
BENT	Between
BR	Beam
BNG	Bearing
BT	Block (as for steel beams)
BLK	Blocking
BLDG	Building
BT	Both Sides
BS	Bottom
BLDG	Building
C, also I	Channel
CAN or C	Canister
CANTILEVER	Cantilever
CIP	Cast-in-Place (Concrete)
CIG	Ceiling
CTR	Center
CL	Center Line
CL	Center of Gravity
C to C	Center to Center
CHAM	Chamber
COL	Column
CJP	Complete Joint Penetration (Weld)
CONC	Concrete
CMU	Concrete Masonry Unit
CRST	Concrete Reinforcing Steel Institute
CONN	Connection
CONSTR	Construction
CONSTR JT	Construction Joint
CONT	Continuous or Continue
CTRL JT or CONTROL JT	Control Joint
CORP	Corporation
CU	Cubic
CU FT or FT ³	Cubic Foot
CU IN or IN ³	Cubic Inch
CU YD or YD ³	Cubic Yard
D or DL	Dead Load
D	Depth
DEF	Deflection
DEG, also °	Degree
DET	Detail
DIAG	Diagram
DIA, also ø	Diameter
DIAPH	Diaphragm
DM	Dimension
DO	Ditto
DN	Down
DRG	Drawing
EA	Each
EP	Each Face
EW	Each Way
E-W	East-West
ELC	Electrical
EL	Elevation
EQ	Equal
EQUIP	Equipment
EQUIV	Equivalent
EXIST	Existing
EXP JT	Expansion Joint
EXT	Exterior
FF	Far Face
FS	Far Side
FIG	Figure
F	Finish
FIN FL	Finish Floor
FIN GR	Finish Grade
FP	Fireproofing
FL	Floor, Floor Line
FT, also °	Foot
GA	Gage
GALV	Galvanized
GEN	General
GR	Grade, Grading
HT	Height
HXP	Hexagonal
H	High
HP	High Point
HOR	Horizontal
H	Horizontal (Force)
IN, also "	Inch
INCL	Include (also)
ID	Inside Diameter
IF	Inside Face
INT	Interior
JT	Joint
K	Kip
K-FT	Kip-Foot
KLF	Kips per Linear Foot
KSF	Kips per Square Foot
KSI	Kips per Square Inch
KD	Kilodisp
L	Length
LT	Light
LM	Lightweight
LN	Linear
L or LL	Live Load
LAFD	Load and Resistance Factor Design
LMB	Long Legs Back to Back (for angles)
LSL	Long-Slotted (Bolt Hole)
LP	Low Point
MFR	Manufacturer
MR	Mark
MATL	Material
MAX	Maximum
MED	Mechanical
MED	Medium
MED	Member
MFR	Manufacturer
MISC	Miscellaneous
NC	Miscellaneous Channel
N	Modulus of Elasticity
Moment	

ABBREVIATION

ABBREVIATION	COMPLETE WORD
NT	Near Face
NS	Near Side
NEG	Negative
NOM	Nominal
NM	Nominal Weight (concrete)
N	North
N-S	North-South
NIC	Not in Contract
NR	Not Reducible (Live Load)
NTS	Not To Scale
NO, also #	Number
OC	On Center(s)
OPG	Opening
OPP	Opposite
OSD	Outside Diameter
OSL	Outside Face
O to O	Out to Out
PP	Partial Penetration Weld
PERM, also I	Permanent
PC	Perpendicular
PL	Piece Mark
PL	Plate
PT	Point
LB	Pound
PCT	Pounds per Cubic Foot
PLP	Pounds per Linear Foot
PSF	Pounds per Square Foot
PSI	Pounds per Square Inch
PRELIM	Preliminary
PROV	Provide (also)
REF	Reference
REIN	Reinforcement (also)
REBAR	Reinforcing Bar
RELLOC	Relocate
REQD	Required
REV	Reverse (also)
RD, also O	Round
SCHED	Schedule (also)
SEC, also "	Second
SECT	Section
SH	Sheet
SLB	Short Legs Back to Back
SL	Similar
SK	Sketch
SLOT	Slot (also)
SP	Specification (also)
SP, also Ø	Square
SQ FT or FT ²	Square Foot
SQ IN or IN ²	Square Inch
STAG	Stagger (also)
SS	Stainless Steel
STD	Standard
STL	Steel
STIFF	Stiffener
STRUT	Structural
STRUT	Superimposed Dead Load
SYMM	Symmetrical
T	Toe Section
TEMP	Temporary
THK	Thickness
THRU	Through
TOL	Tolerance
TCC	Top of Concrete
TOS	Top of Steel
TYP	Typical
ULT	Ultimate
UL	Underwriter's Laboratory, Inc.
UN	Unless Otherwise Noted
VIF	Verify in Field
VERT	Vertical
V	Vertical (Reaction or Force)
WASH	Washer
WT	Weight
WVF	Welded Wire Fabric
W	Wide
W	Wide Flange
W	Width
W or WL	Wind Load
W	With
W/O	Without
WP	Working (Point)
XXS	Double Extra Strong (Pipe)
XS	Extra Strong (Pipe)
YD	Yard
YS	Yield Stress (Steel)
Z	Zee

STRUCTURAL DESIGN CRITERIA

This structural design criteria of the project is for general information only and does not modify, alter or overrule the Specifications or the Contract Drawings.

A. CODES

The design meets or exceeds the requirements of the following codes. In some instances, the more stringent requirements have been applied where appropriate.

- Building Code of the City of New York, 1993 and subsequent supplements.
- Load and Resistance Factor Design Specification for Structural Steel Buildings, 1 September 1986, with Supplement No. 1, 1 January 1989, (AISC-LRFD), by American Institute of Steel Construction.
- ANSI/ANS D1.1, 1990, Structural Welding Code - Steel.
- ACI 318-89, Building Code Requirements for Reinforced Concrete by American Concrete Institute.

B. GRAVITY LOADS

The loads that follow do not include the weight of structural steel members. Normal weight concrete is taken at a unit weight of 150 pcf. Light weight concrete is taken at a unit weight of 117 pcf. Live loads are reducible except where noted NR (not reducible). The following are dead, superimposed dead and live loads taken for each occupancy category:

1. BULKHEAD FLOOR	psf	Notes
Construction Dead Load		
- 4" lightweight concrete slab over 2" metal deck	53	
Superimposed Dead Load		
- fireproofing	2	
- finish	2	
- equipment allowance	-	(1) (3)
Total Superimposed Dead Load	4	(1) (3)
Total Dead Load	57	(1) (3)
Live Load	75 NR	(2)

2. BULKHEAD ROOF

Construction Dead Load	
- 1 1/2" roof metal deck	3
Superimposed Dead Load	
- mechanical/electrical hung from below	10 (1)
- roof finish	20
- 1 1/2" to 4" tapered insulation	
- waterproofing membrane	
1 1/2" pavers	
Total Superimposed Dead Load	30 (1)
Total Dead Load	33 (1)
Live Load	40 NR

3. FUEL OIL TANK ROOM ROOF

Construction Dead Load	
- 4 1/2" lightweight concrete slab over 2" metal deck	58
Superimposed Dead Load	
- fireproofing	2
- mechanical/electrical hung from below	10
Total Superimposed Dead Load	12
Total Dead Load	70
Live Load	30

4. BULKHEAD PERIMETER WALL

A wall load of 20 psf (of wall surface area) is considered around the Bulkhead. The framing of the Bulkhead Floor and the framing of the Bulkhead Roof are each designed to carry the full weight of the perimeter wall. The intermediate tube beam is designed to carry a 10 psf wall load (of wall surface area) between the beam and the Bulkhead Roof.

5. 5 WTC FUEL OIL LINES

- Vertical Runs

The weight of 2" fuel lines, weighing 6 pcf each, between the 5 WTC Roof and the 259 Level, are considered to be supported at the 259 Level. Fuel lines are enclosed by 8" CMU walls inside the shaft, weighing 55 pcf (of wall surface area). Fuel pipe supports are provided at every floor.
- Horizontal Runs

Two 2" fuel pipes inside an 8" SCH40 encasement pipe, all weighing 39 pcf, are considered to be hung from the 5 WTC Roof (Floor 10), between the Generator Room and the riser shaft, and from the 259 Level, between the riser shaft and the Fuel Tank Room.

Vertical supports for the fuel lines are assumed to be at approximately 10 to 12 ft. on center.

The fuel line is considered to be enclosed by a 2 hour fire rated gypsum board enclosure, weighing approximately 40 pcf, directly attached to the structure.

6. ELECTRIC CABLES

- Vertical Runs

Armored cables, weighing 16 pcf each, inside 5" rigid conduits, weighing 13 pcf each, are considered in the riser shafts at 5 WTC, 6 WTC and 7 WTC. The number of cables are shown in the Contract Drawings. Per JPLA, the total weight of cable and conduit (29 pcf) is assumed uniformly distributed between all conduit supports in the run. Conduits are supported at every floor.
- Horizontal Runs

Unless otherwise noted, cables, weighing 8 pcf each, inside 5" rigid conduits, weighing 13 pcf each, are considered to be hung from the existing structure. See Mechanical Drawings for routing of cables.

A 3" concrete encasement, weighing 85 pcf for each conduit, is added where the encasement is indicated in the mechanical drawings. Vertical supports for the cables (and the encasement where required) are assumed to be at approximately 5 ft. on center.

7. FUEL OIL TANK ROOM

It is assumed that one tank may burst, causing the Tank Room to flood to a level of 2.5 ft. The CMU walls surrounding this room are capable of resisting the hydrostatic pressures associated with this flooding.

Notes:

- Actual equipment weights, as provided by JPLA, are added as summarized below. The indicated weights are the total maximum operating weights of the equipment, including base weights, attachments and the like. Except as noted, the equipment is supported by the Bulkhead floor framing. For location of equipment, see Mechanical Drawings.

Generator	42000 lbs
Radiator	9000 lbs
Silencer (2 per generator)	1400 lbs each
Switchgear	25000 lbs
Load Bank	24500 lbs
Pur air Duct Tenant Installation	8000 lbs

• 80% of the weight - supported by the Bulkhead Roof. 20% is added to the Generators. One silencer per generator, weighing 2800 lbs, may be selected instead of the two indicated silencers per generator.

An 18" fuel oil header, weighing 203 pcf and spanning north-south along the Bulkhead length, is considered to be supported from the Bulkhead Roof, just west of the exhaust of the silencers.

- Only Live Load at location of equipment considered in Note 1. Use 50 psf NR (Not Reducible) as aisle live load between generators.

To facilitate installation of the generators, the beams in the area east of the column line spanning between Columns E-10/21 and E-16/7 are designed to accommodate two generators per 30' bay located anywhere within the bay.

Note that the slab is not designed to span the weight of the generators to the beams. During installation, when the generators are moved around in the area indicated above, lifting beams need be placed on top of the slab to transfer the weight of the generators to the supporting floor beams.

THE FORT AUTHORITY OF NY & NJ



ORIGINAL SIGNED & SEALED BY
N.Y. P.E. (OR R.A.)

Joseph P. Long
& Associates, Inc.
consulting engineers

One Pennsylvania Plaza
New York, New York 10004-0045
Tel: (212) 512-7400, Fax: (212) 512-7382

THE OFFICE OF

EDWARD

LEONOWITZ

CONSULTING ENGINEER

IN NEW YORK CITY BY 1988

IN NEW YORK STATE BY 1988

IN PENNSYLVANIA BY 1988

IN DELAWARE BY 1988

IN MARYLAND BY 1988

IN VIRGINIA BY 1988

IN NORTH CAROLINA BY 1988

IN SOUTH CAROLINA BY 1988

IN FLORIDA BY 1988

IN ALABAMA BY 1988

IN MISSISSIPPI BY 1988

IN LOUISIANA BY 1988

IN ARIZONA BY 1988

IN IDAHO BY 1988

IN MONTANA BY 1988

IN WYOMING BY 1988

IN NEVADA BY 1988

IN UTAH BY 1988

IN COLORADO BY 1988

IN WISCONSIN BY 1988

IN ILLINOIS BY 1988

IN INDIANA BY 1988

IN OHIO BY 1988

IN KENTUCKY BY 1988

IN TENNESSEE BY 1988

IN MISSOURI BY 1988

IN IOWA BY 1988

IN NEBRASKA BY 1988

IN KANSAS BY 1988

IN OKLAHOMA BY 1988

IN TEXAS BY 1988

IN CALIFORNIA BY 1988

IN ARIZONA BY 1988

IN NEVADA BY 1988

IN UTAH BY 1988

IN COLORADO BY 1988

IN WISCONSIN BY 1988

IN ILLINOIS BY 1988

IN INDIANA BY 1988

IN OHIO BY 1988

IN KENTUCKY BY 1988

IN TENNESSEE BY 1988

IN MISSOURI BY 1988

IN IOWA BY 1988

IN NEBRASKA BY 1988

IN KANSAS BY 1988

IN OKLAHOMA BY 1988

IN TEXAS BY 1988

IN CALIFORNIA BY 1988

IN ARIZONA BY 1988

IN NEVADA BY 1988

IN UTAH BY 1988

IN COLORADO BY 1988

IN WISCONSIN BY 1988

IN ILLINOIS BY 1988

IN INDIANA BY 1988

IN OHIO BY 1988

IN KENTUCKY BY 1988

IN TENNESSEE BY 1988

IN MISSOURI BY 1988

IN IOWA BY 1988

IN NEBRASKA BY 1988

IN KANSAS BY 1988

IN OKLAHOMA BY 1988

IN TEXAS BY 1988

IN CALIFORNIA BY 1988

IN ARIZONA BY 1988

IN NEVADA BY 1988

IN UTAH BY 1988

IN COLORADO BY 1988

IN WISCONSIN BY 1988

IN ILLINOIS BY 1988

IN INDIANA BY 1988

IN OHIO BY 1988

IN KENTUCKY BY 1988

IN TENNESSEE BY 1988

IN MISSOURI BY 1988

IN IOWA BY 1988

IN NEBRASKA BY 1988

IN KANSAS BY 1988

IN OKLAHOMA BY 1988

IN TEXAS BY 1988

IN CALIFORNIA BY 1988

IN ARIZONA BY 1988

IN NEVADA BY 1988

IN UTAH BY 1